IEEE Standards

IEEE Std 101 7™-2004
(Revision of
IEEE Std 1017-
1991)

101 7™

IEEE Recommended Practice for Field Testing Electric Submersible Pump Cable

IEEE Industry Applications Society

Sponsored by the
Petroleum and Chemical Industry Committee

IEEE

3 Park Avenue, New York, NY 10016-5997, USA

13 April 2005

Print: SH95250
PDF: SS95250

HALLIBURTON EXHIBIT 2016
Profrac Holding Corporation and U.S. Well Services, LLC v. Halliburton Energy Services, Inc.
IPR2023-01318, page 1

Recognized as an
American National Standard (ANSI)

IEEE Std 1017™-2004
(Revision of
IEEE Std 1017-1991)

IEEE Recommended Practice for Field Testing Electric Submersible Pump Cable

Sponsored by

Petroleum and Chemical Industry Committee
of the
IEEE Industry Applications Society

Approved 10 March 2005

American National Standards Institute

Approved 23 September 2004

IEEE-SA Standards Board

Abstract: Procedures and test voltage values for acceptance and maintenance testing of electrical submersible pump (ESP) cable systems are presented. This recommended practice applies to cable systems rated 3 kV and 5 kV (phase to phase) and is intended only for this special-purpose cable. The intent is to provide uniform test procedures and guidelines for evaluation of the test results.

Keywords: cable ampacity, cable testing, conductors, field testing, submersible pump cable

---

The Institute of Electrical and Electronics Engineers, Inc.
3 Park Avenue, New York, NY 10016-5997, USA

Copyright © 2005 by the Institute of Electrical and Electronics Engineers, Inc.
All rights reserved. Published 13 April 2005. Printed in the United States of America.

IEEE is a registered trademark in the U.S. Patent & Trademark Office, owned by the Institute of Electrical and Electronics Engineers, Incorporated.

National Electrical Code and NEC are registered trademarks in the U.S. Patent & Trademark Office, owned by The National Fire Protection Association.

Print: ISBN 0-7381-4077-5 SH95250
PDF: ISBN 0-7381-4078-3 SS95250

No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher.

IEEE Standards documents are developed within the IEEE Societies and the Standards Coordinating Committees of the IEEE Standards Association (IEEE-SA) Standards Board. The IEEE develops its standards through a consensus development process, approved by the American National Standards Institute, which brings together volunteers representing varied viewpoints and interests to achieve the final product. Volunteers are not necessarily members of the Institute and serve without compensation. While the IEEE administers the process and establishes rules to promote fairness in the consensus development process, the IEEE does not independently evaluate, test, or verify the accuracy of any of the information contained in its standards.

Use of an IEEE Standard is wholly voluntary. The IEEE disclaims liability for any personal injury, property or other damage, of any nature whatsoever, whether special, indirect, consequential, or compensatory, directly or indirectly resulting from the publication, use of, or reliance upon this, or any other IEEE Standard document.

The IEEE does not warrant or represent the accuracy or content of the material contained herein, and expressly disclaims any express or implied warranty, including any implied warranty of merchantability or fitness for a specific purpose, or that the use of the material contained herein is free from patent infringement. IEEE Standards documents are supplied "**AS IS**."

The existence of an IEEE Standard does not imply that there are no other ways to produce, test, measure, purchase, market, or provide other goods and services related to the scope of the IEEE Standard. Furthermore, the viewpoint expressed at the time a standard is approved and issued is subject to change brought about through developments in the state of the art and comments received from users of the standard. Every IEEE Standard is subjected to review at least every five years for revision or reaffirmation. When a document is more than five years old and has not been reaffirmed, it is reasonable to conclude that its contents, although still of some value, do not wholly reflect the present state of the art. Users are cautioned to check to determine that they have the latest edition of any IEEE Standard.

In publishing and making this document available, the IEEE is not suggesting or rendering professional or other services for, or on behalf of, any person or entity. Nor is the IEEE undertaking to perform any duty owed by any other person or entity to another. Any person utilizing this, and any other IEEE Standards document, should rely upon the advice of a competent professional in determining the exercise of reasonable care in any given circumstances.

Interpretations: Occasionally questions may arise regarding the meaning of portions of standards as they relate to specific applications. When the need for interpretations is brought to the attention of IEEE, the Institute will initiate action to prepare appropriate responses. Since IEEE Standards represent a consensus of concerned interests, it is important to ensure that any interpretation has also received the concurrence of a balance of interests. For this reason, IEEE and the members of its societies and Standards Coordinating Committees are not able to provide an instant response to interpretation requests except in those cases where the matter has previously received formal consideration. At lectures, symposia, seminars, or educational courses, an individual presenting information on IEEE standards shall make it clear that his or her views should be considered the personal views of that individual rather than the formal position, explanation, or interpretation of the IEEE.

Comments for revision of IEEE Standards are welcome from any interested party, regardless of membership affiliation with IEEE. Suggestions for changes in documents should be in the form of a proposed change of text, together with appropriate supporting comments. Comments on standards and requests for interpretations should be addressed to:

Secretary, IEEE-SA Standards Board
445 Hoes Lane

Piscataway, NJ 08854

USA

NOTE-Attention is called to the possibility that implementation of this standard may require use of subject matter covered by patent rights. By publication of this standard, no position is taken with respect to the existence or validity of any patent rights in connection therewith. The IEEE shall not be responsible for identifying patents for which a license may be required by an IEEE standard or for conducting inquiries into the legal validity or scope of those patents that are brought to its attention.

Authorization to photocopy portions of any individual standard for internal or personal use is granted by the Institute of Electrical and Electronics Engineers, Inc., provided that the appropriate fee is paid to Copyright Clearance Center. To arrange for payment of licensing fee, please contact Copyright Clearance Center, Customer Service, 222 Rosewood Drive,

Danvers, MA 01923 USA; +1 978 750 8400. Permission to photocopy portions of any individual standard for educational classroom use can also be obtained through the Copyright Clearance Center.

No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher.

Introduction

This introduction is not part of IEEE Std 1017-2004, IEEE Recommended Practice for Field Testing Electric Submersible Pump Cable.

This recommended practice, under the jurisdiction of the Petroleum and Chemical Industry Committee of the IEEE Industry Applications Society, may be used by anyone desiring to do so and is presented as minimum criteria for construction of this class of submersible cable. It is not intended to restrict innovation or to limit development of improvements in cable design. Every effort has been made to assure the accuracy and reliability of the data contained herein. However, the committee makes no representation, warranty, or guarantee in connection with the publication of this recommended practice and hereby expressly disclaims any liability or responsibility for loss or damage resulting from its use, for any conflict, or for the infringement of any patent resulting from the use of this recommended practice.

Notice to users

Errata

Errata, if any, for this and all other standards can be accessed at the following URL: http://standards.ieee.org/reading/ieee/updates/errata/index.html. Users are encouraged to check this URL for errata periodically.

Interpretations

Current interpretations can be accessed at the following URL: http://standards.ieee.org/reading/ieee/interp/index.html.

Patents

Attention is called to the possibility that implementation of this standard may require use of subject matter covered by patent rights. By publication of this standard, no position is taken with respect to the existence or validity of any patent rights in connection therewith. The IEEE shall not be responsible for identifying patents or patent applications for which a license may be required to implement an IEEE standard or for conducting inquiries into the legal validity or scope of those patents that are brought to its attention.

Participants

The following is a list of participants in the Downhole Working Group of the Petroleum and Chemical Industry Committee.

Marcus O. Durham, *Chair*

Thomson H. Wallace, *Secretary*

David Anderson
Gordon Baker
Lester Gagan
Robert Lannom
Howard Oswald
John Patterson
Rodney Story

Copyright © 2005 IEEE. All rights reserved.

HALLIBURTON EXHIBIT 2016
Profrac Holding Corporation and U.S. Well Services, LLC v. Halliburton Energy Services, Inc.
IPR2023-01318, page 6

The following members of the individual balloting committee voted on this recommended practice. Balloters may have voted for approval, disapproval, or abstention.

Kaveh Ashenayi
James M. Daly
Gary Donner
Marcus O. Durham
Richard H. Hulett
Ben C. Johnson
Lorraine K. Padden
Tom P. Pearson

When the IEEE-SA Standards Board approved this recommended practice on 23 September 2004, it had the following membership:

Don Wright, *Chair*
Steve M. Mills, *Vice Chair*
Judith Gorman, *Secretary*

Chuck Adams
Stephen Berger
Mark D. Bowman
Joseph A. Bruder
Bob Davis
Roberto de Marca Boisson
Julian Forster*
Arnold M. Greenspan
Mark S. Halpin
Raymond Hapeman
Richard J. Holleman
Richard H. Hulett
Lowell G. Johnson
Joseph L. Koepfinger*
Hermann Koch
Thomas J. McGean
Daleep C. Mohla
Paul Nikolich
T. W. Olsen
Ronald C. Petersen
Gary S. Robinson
Frank Stone
Malcolm V. Thaden
Doug Topping
Joe D. Watson

*Member Emeritus

Also included are the following nonvoting IEEE-SA Standards Board liaisons:

Satish K. Aggarwal, *NRC Representative*
Richard DeBlasio, *DOE Representative*
Alan Cookson, *NIST Representative*

Michael D. Fisher
IEEE Standards Project Editor

Copyright © 2005 IEEE. All rights reserved.
HALLIBURTON EXHIBIT 2016
Profrac Holding Corporation and U.S. Well Services, LLC v. Halliburton Energy Services, Inc.
IPR2023-01318, page 7

Contents

1. Overview 1

1.1 Scope 1
1.2 Purpose 2

2. Normative references 2

3. Definitions 2

4. Safety 5

4.1 Description 5
4.2 Application 5
4.3 Procedures to secure cable and area 5

5. General considerations 6

5.1 Environmental influences 6
5.2 Test equipment 6
5.3 Equipment setup 7
5.4 Special fault-locating test equipment 7
5.5 Equipment maintenance 7

6. DC high-pot test methods 8

6.1 Precautions 8
6.2 Procedures 8

7. Evaluation of dc high-pot test results 13

7.1 Current-time relationship 13
7.2 Interpretation 13
7.3 Dielectric failure 16
7.4 Current comparison 16

8. Conductor resistivity and continuity tests 17

9. Mechanical integrity 17

10. Testing of surface feedthroughs and connections 17

10.1 Description 17
10.2 Wellhead with feedthrough 18
10.3 Wellhead with connections 18
10.4 Test procedure 18
10.5 Visual inspection 19
10.6 Procedure 19

Annex A (informative) Bibliography 20

Copyright © 2005 IEEE. All rights reserved.

HALLIBURTON EXHIBIT 2016
Profrac Holding Corporation and U.S. Well Services, LLC v. Halliburton Energy Services, Inc.
IPR2023-01318, page 8

IEEE Recommended Practice for Field Testing Electric Submersible Pump Cable

1. Overview

Guidance for the field and maintenance testing of conventional power cable is available in IEEE Std 400™[1]; however, that document is not an applicable guide in assessing the condition of electric submersible pump (ESP) cable. By adopting some principles set forth in IEEE Std 400 and applying others developed from field experience, this recommended practice for submersible cable testing will assist those persons with the responsibility of determining the dielectric condition of this type of cable.

This recommended practice proposes the use of direct current (dc) because of its advantages over alternating current (ac). These advantages are as follows:

a) Smaller test equipment may be used.

b) It minimizes damage, which aids in fault examination.

This recommended practice is for cables without a connecting motor-lead extension cable or surface connecting cable, and it is primarily for armored cables; however, unarmored cables can be tested by submersing them in water.

This recommended practice does not require that testing be performed, either at the time of installation or periodically thereafter, for acceptance or maintenance. It sets forth the consensus of currently known good practice in testing methods, with interpretation of results.

1.1 Scope

Procedures and test voltage values for acceptance and maintenance testing of ESP cable systems are presented. This procedure applies to cable systems rated 3 kV and 5 kV (phase to phase).

[1]Information on references can be found in Clause 2.

Copyright © 2005 IEEE. All rights reserved.

HALLIBURTON EXHIBIT 2016
Profrac Holding Corporation and U.S. Well Services, LLC v. Halliburton Energy Services, Inc.
IPR2023-01318, page 11

1.2 Purpose

The purpose of this recommended practice is as follows:

a) Provide a guideline for performing leakage current so it can be used as a cable quality tool
b) Provide guidelines for evaluation of the test results
c) Define terms that have a specific meaning to the recommended practice

2. Normative references

The following referenced documents are indispensable for the application of this recommended practice. For dated references, only the edition cited applies. For undated references, the latest edition of the reference document (including any amendments or corrigenda) applies.

API RP 11 S4, Recommended Practice for Sizing and Selection of Electric Submersible Pump Installation, 3rd ed.[2]

API RP 11S5, Recommended Practice for Application of Electric Submersible Pump Cable Systems, 1st ed.

API RP 11S6, Recommended Practice for Testing of Electric Submersible Pump Cable Systems, 1st ed.

API RP 500, Classification of Locations for Electrical Installation at Petroleum Facilities Classified as Class 1, Division 1, and Division 2.

IEEE Std 400™, IEEE Guide for Field Testing and Evaluation of the Insulation of Shielded Power Cable Systems.[3, 4]

IEEE Std 101 8™, IEEE Recommended Practice for Specifying Electric Submersible Pump Cable—Ethylene-Propylene Rubber Insulation.

IEEE Std 1019™, IEEE Recommended Practice for Specifying Electric Submersible Pump Cable—Polypropylene Insulation.

NFPA 70, National Electrical Code® (NEC®).[5, 6]

3. Definitions

For the purposes of this standard, the following terms and definitions apply. IEEE 100, *The Authoritative Dictionary of IEEE Standards Terms,* Seventh Edition [B3] should be referenced for terms not defined in this clause.[7]

3.1 absorption current: Current resulting from charge absorbed into the dielectric as a result of polarization.

[2]API publications are available from the Publications Section, American Petroleum Institute, 1200 L Street NW, Washington, DC 20005, USA (http://www.api.org/).

[3]The IEEE standards or products referred to in this clause are trademarks of the Institute of Electrical and Electronics Engineers, Inc.

[4]IEEE publications are available from the Institute of Electrical and Electronics Engineers, Inc., 445 Hoes Lane, Piscataway, NJ 08854, USA (http://standards.ieee.org/).

[5]National Electrical Code and NEC are both registered trademarks of the National Fire Protection Association, Inc.

[6]NFPA publications are available from Publications Sales, National Fire Protection Association, 1 Batterymarch Park, P.O. Box 9101, Quincy, MA 02269-9101, USA (http://www.nfpa.org/).

[7]The numbers in brackets correspond to those of the bibliography in Annex A.

Copyright © 2005 IEEE. All rights reserved.
HALLIBURTON EXHIBIT 2016
Profrac Holding Corporation and U.S. Well Services, LLC v. Halliburton Energy Services, Inc.
IPR2023-01318, page 12

3.2 ac test: This test is performed by the manufacturer as a pass/fail test to ensure the electrical integrity of the cable.

3.3 acceptance test: This test is intended to detect damage before the initial installation of new cable. These tests are normally performed by the user or the designated representative using dc voltage at 80% of the factory test voltage.

3.4 capacitance current: Current required to charge the capacitor formed by the dielectric of the cable under test.

3.5 dc test: This test is performed by the manufacturer to ensure the electrical integrity of the cable. The conductance leakage current is used as a comparative measurement, and the dc voltage can be used as a pass/fail test.

3.6 electric submersible pumps (ESPs): Equipment that refers to electric-driven, deep-well centrifugal pumps as commonly used to lift fluids from subsurface formations.

NOTE—Refer to Figure 1 for typical assembly.[8]



Figure 1—Typical ESP cable

[8]Notes in text, tables, and figures are given for information only, and do not contain requirements needed to implement the standard.

Copyright © 2005 IEEE. All rights reserved.

HALLIBURTON EXHIBIT 2016
Profrac Holding Corporation and U.S. Well Services, LLC v. Halliburton Energy Services, Inc.
IPR2023-01318, page 13

3.7 ESP cable: Three-conductor power cable is installed in the well for the purpose of transmitting power from the surface to the motor or motor-lead extension cable.

3.8 factory test: This test is completed by the manufacture at the 100% level. This voltage test is conducted phase to ground.

NOTE—See Table 1.

Table 1—Test voltages for ESP cable[a]

Cable dating (kV rms) (phase-to-phase)	Factory test voltage (kV)	Acceptance test voltage[b] (kV)	Maintenance test voltage[c] (kV)
3	27	22	11
5	35	28	14

[a]All tests are dc, conductor to ground for 5 minutes.
[b]Acceptance test is 80% of factory test.
[c]Maintenance test is 40% of factory test.

3.9 field: This term or the term "in the field" may include cable not yet installed or cable that has been removed from its operating environment.

3.10 insulation resistance (IR): The opposition to current flow through the insulation.

3.11 insulation resistance test: By impressing a dc voltage across the insulation, a leakage current will be produced through the insulation. The ratio of voltage to current is the insulation resistance of the cable. A megohmmeter is used to perform this test.

3.12 leakage current (conductance): Current resulting from leakage through the cable insulating medium and over surfaces of cable connections and terminations. This leakage current is measured using a test set equipped with an accurate microampere meter. Corona discharge from external energized elements are also included.

3.13 maintenance test: This test is made after removing the cable from a well and is normally performed by the user or the designated representative using dc voltage at 40% of the factory test voltage. It is intended to detect the deterioration of the cable insulation and to determine suitability for reuse. It is also sometimes referred to as proof testing.

3.14 motor lead extension cable: Three-conductor cable normally designed with a high-temperature/high-dielectric insulation to allow the smallest cable possible. This cable runs from above the pump to the motor including the motor connecting plug.

3.15 rated voltage: This term is expressed for phase-to-phase voltage of a three-phase system.

3.16 surface connection cable: Power cable connecting the ESP cable to surface equipment. Sometimes, it is referred to as a "surface cable."

Copyright © 2005 IEEE. All rights reserved.
HALLIBURTON EXHIBIT 2016
Profrac Holding Corporation and U.S. Well Services, LLC v. Halliburton Energy Services, Inc.
IPR2023-01318, page 14

4. Safety

4.1 Description

Testing of cable systems using high-voltage dc testing involves all hazards that are normally associated with working on energized circuits and several unique hazards that should be addressed.

4.2 Application

Cables that are tested using dc voltage can hold an electrical charge for long periods of time after voltage has been removed. This electrical charge is maintained because of the high capacitance and dielectric absorption characteristics of the insulation. This buildup of an electrical charge is characteristic of all insulating materials.

WARNING

Cable subjected to high-voltage dc testing that is not properly grounded after the test can have dangerous charge buildup. Proper grounding procedures shall be followed to eliminate personnel hazards.

4.3 Procedures to secure cable and area

Cable testing is best performed in a designated area designed for the sole purpose of inspecting and testing of cable. Equipment should be maintained, calibrated, and checked at regular intervals to ensure that equipment is in working order and that the grounding system is functional. It is recommended that a strobe light be incorporated into the unit to indicate that the system has been energized.

Cable circuits normally have one or more ends that are remote from the location of the test equipment and test operator. These ends should be cleared and guarded to ensure the safety of personnel. Voice communication should be established between all such locations and the test operator. Before a cable is energized, make sure the area is clear of personnel.

All ends as well as all connecting leads of components being tested require guarding from accidental contact by such means as rope barriers, enclosures, or a watchman at all hidden points. The ends require separation from all elements not to be subjected to test by a distance of not less than 15 cm (5.9 in).

All components should be de-energized before starting any work. A grounded connection should be applied to each conductor, the armor, and all nonenergized metallic parts in the vicinity. The only time a ground connection should be removed is when applying test voltage to that insulated conductor.

When dc voltages are applied to the cable, it is common for a residual charge to remain in the insulation. After the cable is tested, each conductor should be discharged to ground. A grounded connection should be reattached to the conductor. The ground should be applied long enough to completely discharge the cable. This requirement may be up to four times the duration of the applied voltage. Otherwise there is danger of electrical shock even without an applied voltage.

Additional precautions should be followed after completing tests with dc voltages greater than 5 kV. Connect all conductors and the armor (group tie) to ground (normally the steel reel).

Copyright © 2005 IEEE. All rights reserved.

HALLIBURTON EXHIBIT 2016
Profrac Holding Corporation and U.S. Well Services, LLC v. Halliburton Energy Services, Inc.
IPR2023-01318, page 15

5. General considerations

5.1 Environmental influences

5.1.1 Temperature

The dielectric strength of cable insulation is reduced at elevated temperatures. Therefore, surface cable tests should be conducted after the cable has cooled to surface ambient temperature and the cable has had a chance to degas.

5.1.2 Environmental conditions

High humidity and conditions favoring condensation on exposed surfaces can affect test results to a marked degree. Contamination can greatly increase conduction current and increase the potential for flashover. Relative air density affects the measurement of test voltage and may cause a flashover at the termination. At elevations higher than 1000 m (3280 ft), additional insulation of the cable ends is required to withstand the prescribed test voltages. Wind can cause erroneous current reading. Consequently, all of these factors should be considered when conducting cable tests.

5.1.3 Oilwell liquids and gases

High humidity and conditions favoring condensation on exposed surfaces can affect test results to a marked degree. Contamination can greatly increase conduction current and increase the potential for flashover. Relative air density affects the measurement of test voltage and may cause a flashover at the termination. At elevations higher than 1000 m (3280 ft), additional insulation of the cable ends is required to withstand the prescribed test voltages. Wind can cause erroneous current reading. Consequently, all of these factors should be considered when conducting cable tests.

5.2 Test equipment

5.2.1 DC high potential tester (hi-pot)

Equipment should provide

— The maximum voltage required

— Means of increasing voltage continuously or in small steps from zero to the maximum limit

— Output voltage regulation — Filtered dc voltage output — Voltage and current indicators (current indicator should read in microamperes)

— Negative polarity to the cable conductor

— Meter accuracy at least 2% full scale

— A ground position for discharging the cable

5.2.2 Insulation resistance meter

Resistance-measuring instruments by themselves are not recommended for testing the reliability of ESP cable. The output voltage is insufficient to establish a conductive path across insulation defects and will only indicate gross defects.

Insulation resistance measurements are used as the cable is being lowered into the well. These readings provide an indication to the systems reliability. As the unit is lowered into the well, IR can be expected to drop off significantly due to the increase in well temperature.

Copyright © 2005 IEEE. All rights reserved.
HALLIBURTON EXHIBIT 2016
Profrac Holding Corporation and U.S. Well Services, LLC v. Halliburton Energy Services, Inc.
IPR2023-01318, page 16

5.3 Equipment setup

Check the operation of the test set in accordance with the manufacturers' recommendations. The equipment leakage current indication can be checked by connecting a short piece of small uninsulated wire to the test lead. Raise the voltage until corona is heard on the ends of the wire, and check for a current reading on the microampere meter. Then isolate the test lead and cover with plastic material, if necessary, to reduce corona. Raise the voltage to the test value. If leakage current in the test equipment is substantial, this current should be measured and subtracted from the test-current readings.

5.4 Special fault-locating test equipment

5.4.1 Time domain reflectometer (TDR)

TDRs use high-frequency pulses to detect anomalies in the cable. A TDR sends a pulse down the cable, and then the reflective signal is measured. This measurement indicates where the fault should be located. The TDR requires interpretation from an experienced operator.

Communication-type TDRs are designed for low-voltage cable and will not detect minor faults in high-voltage insulation. The power-type TDRs impress a larger voltage on the cable to overcome insulation resistance before the impulse is applied and measured.

5.4.2 Thumper

A high-voltage capacitive discharge is applied to a cable when using a thumper. It is sometimes used to break down conductor insulation to locate a fault. However, this approach creates extreme stress on the cable insulation. If improperly used, it can actually create faults in otherwise good cable. This method is normally not recommended for testing cable and should only be used by experienced personnel for isolating the fault location.

5.4.3 Bridge type fault locator

A bridge-type fault locator uses a balancing bridge in conjunction with high dc voltage to measure conductor impedance (distance) to a fault. This is one of the least destructive types of fault-locating equipment, and it is relatively effective. However, if a high-resistance fault is present, this device may not be effective. This test device is also referred to as a Murry loop.

5.4.4 DC burn

A dc voltage (5–10 kV) is applied to a faulted cable. The voltage is allowed to remain until the fault becomes obvious.

5.5 Equipment maintenance

To ensure accuracy of cable tests, periodic maintenance tests and calibrations should be performed on the test equipment. These procedures should follow the manufacturers' recommended practices. A label showing the latest calibration date should be affixed to the instrument. For some applications, it may be desirable to use outside certifications traceable to the National Institute of Standards and Technology.

Copyright © 2005 IEEE. All rights reserved.

HALLIBURTON EXHIBIT 2016
Profrac Holding Corporation and U.S. Well Services, LLC v. Halliburton Energy Services, Inc.
IPR2023-01318, page 17

6. DC high-pot test methods

6.1 Precautions

Barriers, enclosures, or watchmen should be used to prevent anyone from coming into accidental contact with the cable during testing. The ends require separation from all elements not subject to test by distances not less than 15 cm (5.9 in).

CAUTION

Distances for personnel safety will be significantly greater. Users should comply with all applicable safety codes.

To improve the accuracy of the test, it is desirable to reduce corona leakage current at the bare metal extremities of the cable by covering these with plastic bags, silicone sealant, or electrical putty to reduce stress concentrations.

Environmental conditions as outlined in 5.1.2 can cause erroneous meter readings. In addition, conducting cable tests when there is high humidity, when it is snowing or raining, or when actual precipitation is present on cable surfaces can be hazardous to equipment and personnel due to the likely chance of flashover.

6.2 Procedures

Remove approximately 30 cm (12 in) of armor and outer coverings from each cable end to expose clean insulation. Then separate and spread phase conductors as shown in Figure 2. Remove approximately 2.5 cm (1 in) of insulation from phase conductors at the test set end, and buff the exposed metallic conductors. Clean the exposed insulation with a clean cloth and/or a non-residue-approved solvent to minimize stray current and prevent flashover.



Figure 2—High-voltage dc cable test conditions

Each conductor should be tested separately with the remaining conductors grounded. The ground lead for the test set should also be connected to the power-source ground, supporting metallic structures, and the cable armor.

Before applying the test voltage, the cable should be allowed to cool to ambient surface temperature. The voltage may be increased continuously or in steps to the maximum test value. If increased continuously, the rate should be approximately 1 kV/s. This rate prevents impulse stresses on the insulation. If the step method of voltage increase is employed, a minimum of three steps is desirable. Duration at each step should be long

Copyright © 2005 IEEE. All rights reserved.
HALLIBURTON EXHIBIT 2016
Profrac Holding Corporation and U.S. Well Services, LLC v. Halliburton Energy Services, Inc.
IPR2023-01318, page 18

enough for the current to reach a steady value (1 minute minimum) before taking a current reading. Apply voltage slowly to prevent an off-scale meter indication.

Maximum test voltage should be maintained for 5 minutes. Conductance leakage should be noted at 1 minute intervals for 5 minutes and after the maximum test voltage has been reached. Figure 3 depicts a typical step voltage test sequence for maintenance testing. Table 2 through Table 9 indicate the recommended maximum study-state leakage current. These values are based on theory developed by Durham et al. [B 1].

STEP VOLTAGE TESTING
TO IEEE 1017

Figure 3—High-voltage dc step test



Table 2—Polypropylene acceptance testing

Values for 1.91 mm (75 mil) insulation thickness 3 kV polypropylene					
Conductor	**Conductor diameter**	**Insulation minimum point**	**Calculated insulation diameter**	**IR value 1 km (1 kft)**	**DC leakage 1 km (1 kft)**
Trade size	**mm (in)**	**mm (in)**	**mm (in)**	**MΩ**	**μA/kV**
10 mm^2	3.56 (0.140)	1.73 (0.068)	7.01 (0.302)	3594 (11 791)	0.28 (0.08)
6 Awg	4.11 (0.162)	1.73 (0.068)	7.57 (0.324)	3227 (10588)	0.31 (0.09)
16 mm^2	4.52 (0.178)	1.73 (0.068)	8.01 (0.340)	3005 (9 860)	0.33 (0.10)
4 Awg	5.18 (0.204)	1.73 (0.068)	8.66 (0.367)	2694 (8 840)	0.37 (0.11)
25 mm^2	6.55 (0.258)	1.73 (0.068)	10.01 (0.420)	2241 (7 355)	0.45 (0.14)
2 Awg	7.42 (0.292)	1.73 (0.068)	10.87 (0.454)	2025 (6642)	0.49 (0.15)
1 Awg	8.43 (0.332)	1.73 (0.068)	11.89 (0.494)	1818 (5 964)	0.55 (0.17)
1/0 Awg	9.35 (0.368)	1.73 (0.068)	12.80 (0.530)	1664 (5458)	0.60 (0.18)
2/0 Awg	10.52 (0.414)	1.73 (0.068)	14.00 (0.576)	1504 (4934)	0.67 (0.20)

Copyright © 2005 IEEE. All rights reserved.

HALLIBURTON EXHIBIT 2016
Profrac Holding Corporation and U.S. Well Services, LLC v. Halliburton Energy Services, Inc.
IPR2023-01318, page 19

Table 3—Polypropylene acceptance testing

Values for 2.29 mm (90 mil) insulation thickness 5 kV polypropylene					
Conductor	**Conductor diameter**	**Insulation minimum point**	**Calculated insulation diameter**	**IR value 1 km (1 kft)**	**DC leakage 1 km (1 kft)**
Trade size	**mm (in**	**mm (in)**	**mm (in)**	**MΩ**	**μA/kV**
10 mm^2	3.56 (0.140)	2.06 (0.081)	7.01 (0.302)	4071 (13 355)	0.25 (0.08)
6 Awg	4.11 (0.162)	2.06 (0.081)	7.57 (0.324)	3670 (12 041)	0.27 (0.08)
16 mm^2	4.52 (0.178)	2.06 (0.081)	8.01 (0.340)	3427 (11 242)	0.29 (0.09)
4 Awg	5.18 (0.204)	2.06 (0.081)	8.66 (0.367)	3095 (10 154)	0.32 (0.10)
25 mm^2	6.55 (0.258)	2.06 (0.08 1)	10.01 (0.420)	2580 (8465)	0.39 (0.12)
2 Awg	7.42 (0.292)	2.06 (0.08 1)	10.87 (0.454)	2337 (7 667)	0.43 (0.13)
1 Awg	8.43 (0.332)	2.06 (0.08 1)	11.89 (0.494)	1104 (6 903)	0.48 (0.14)
1/0 Awg	9.35 (0.368)	2.06 (0.081)	12.80 (0.530)	1900 (6235)	0.53 (0.15)
2/0 Awg	10.52 (0.414)	2.06 (0.081)	14.00 (0.576)	1749 (5 737)	0.57 (0.17)

Table 4—Polypropylene maintenance testing

Values for 1.91 mm (75 mil) insulation thickness 3 kV polypropylene					
Conductor	**Conductor diameter**	**Insulation minimum point**	**Calculated insulation diameter**	**IR value 1 km (1 kft)**	**DC leakage 1 km (1 kft)**
Trade size	**mm (in)**	**mm (in)**	**mm (in)**	**MΩ**	**μA/kV**
10 mm^2	3.56 (0.140)	1.73 (0.068)	7.01 (0.302)	1797 (5896)	0.56 (0.17)
6 Awg	4.11 (0.162)	1.73 (0.068)	7.57 (0.324)	1614 (5294)	0.62 (0.19)
16 mm^2	4.52 (0.178)	1.73 (0.068)	8.01 (0.340)	1503 (4930)	0.67 (0.20)
4 Awg	5.18 (0.204)	1.73 (0.068)	8.66 (0.367)	1352 (4437)	0.74 (0.23)
25 mm^2	6.55 (0.258)	1.73 (0.068)	10.01 (0.420)	1121 (3678)	0.89 (0.27)
2 Awg	7.42 (0.292)	1.73 (0.068)	10.87 (0.454)	1012 (3321)	0.99 (0.30)
1 Awg	8.43 (0.332)	1.73 (0.068)	11.89 (0.494)	909 (2982)	1.10 (0.34)
1/0 Awg	9.35 (0.368)	1.73 (0.068)	12.80 (0.530)	832 (2729)	1.20 (0.37)
2/0 Awg	10.52 (0.414)	1.73 (0.068)	14.00 (0.576)	752 (2467)	1.33 (0.41)

Copyright © 2005 IEEE. All rights reserved.
HALLIBURTON EXHIBIT 2016
Profrac Holding Corporation and U.S. Well Services, LLC v. Halliburton Energy Services, Inc.
IPR2023-01318, page 20

Table 5—Polypropylene maintenance testing

Values for 2.29 mm (90 mil) insulation thickness 5 kV polypropylene					
Conductor	**Conductor diameter**	**Insulation minimum point**	**Calculated insulation diameter**	**IR value 1 km (1 kft)**	**DC leakage 1 km (1 kft)**
Trade size	**mm (in)**	**mm (in)**	**mm (in)**	**MΩ**	**μA/kV**
10 mm^2	3.56 (0.140)	2.06 (0.081)	7.01 (0.302)	2035 (6678)	0.49 (0.15)
6 Awg	4.11 (0.162)	2.06 (0.081)	7.57 (0.324)	1835 (6020)	0.55 (0.17)
16 mm^2	4.52 (0.178)	2.06 (0.081)	8.01 (0.340)	1713 (5621)	0.58 (0.18)
4 Awg	5.18 (0.204)	2.06 (0.08 1)	8.66 (0.367)	1548 (5077)	0.65 (0.20)
25 mm^2	6.55 (0.258)	2.06 (0.08 1)	10.01 (0.420)	1290 (4232)	0.78 (0.24)
2 Awg	7.42 (0.292)	2.06 (0.081)	10.87 (0.454)	1168 (3834)	0.86 (0.26)
1 Awg	8.43 (0.332)	2.06 (0.08 1)	11.89 (0.494)	1052 (3452)	0.95 (0.29)
1/0 Awg	9.35 (0.368)	2.06 (0.081)	12.80 (0.530)	950 (3118)	1.05 (0.32)
2/0 Awg	10.52 (0.414)	2.06 (0.081)	14.00 (0.576)	874 (2868)	1.14 (0.35)

Table 6—Ethylene-propylene diene monomer (EPDM) acceptance testing

Values for 1.91 mm (75 mil) insulation thickness 3 kV EPDM					
Conductor	**Conductor diameter**	**Insulation minimum point**	**Calculated insulation diameter**	**IR value 1 km (1 kft)**	**DC leakage 1 km (1 kft)**
Trade size	**mm (in)**	**mm (in)**	**mm (in)**	**MΩ**	**μA/kV**
10 mm^2	3.56 (0.140)	1.73 (0.068)	7.01 (0.302)	1438 (4717)	0.69 (0.21)
6 Awg	4.11 (0.162)	1.73 (0.068)	7.57 (0.324)	1291 (4235)	0.78 (0.24)
16 mm^2	4.52 (0.178)	1.73 (0.068)	8.01 (0.340)	1202 (3944)	0.83 (0.25)
4 Awg	5.18 (0.204)	1.73 (0.068)	8.66 (0.367)	1082 (3550)	0.92 (0.28)
25 mm^2	6.55 (0.258)	1.73 (0.068)	10.01 (0.420)	897 (2942)	1.12 (0.34)
2 Awg	7.42 (0.292)	1.73 (0.068)	10.87 (0.454)	810 (2657)	1.24 (0.38)
1 Awg	8.43 (0.332)	1.73 (0.068)	11.89 (0.494)	727 (2386)	1.38 (0.42)
1/0 Awg	9.35 (0.368)	1.73 (0.068)	12.80 (0.530)	666 (2186)	1.50 (0.46)
2/0 Awg	10.52 (0.414)	1.73 (0.068)	14.00 (0.576)	602 (1974)	1.66 (0.51)

Copyright © 2005 IEEE. All rights reserved.

HALLIBURTON EXHIBIT 2016
Profrac Holding Corporation and U.S. Well Services, LLC v. Halliburton Energy Services, Inc.
IPR2023-01318, page 21

Table 7—EPDM acceptance testing

Values for 2.29 mm (90 mil) insulation thickness 5 kV EPDM					
Conductor	**Conductor diameter**	**Insulation minimum point**	**Calculated insulation diameter**	**IR value 1 km (1 kft)**	**DC leakage 1 km (1 kft)**
Trade size	**mm (in)**	**mm (in)**	**mm (in)**	**MΩ**	**μA/kV**
10 mm^2	3.56 (0.140)	2.06 (0.081)	7.01 (0.302)	1628 (5342)	0.61 (0.19)
6 Awg	4.11 (0.162)	2.06 (0.081)	7.57 (0.324)	1468 (4817)	0.68 (0.21)
16 mm^2	4.52 (0.178)	2.06 (0.081)	8.01 (0.340)	1370 (4497)	0.73 (0.22)
4 Awg	5.18 (0.204)	2.06 (0.081)	8.66 (0.367)	1238 (4062)	0.81 (0.25)
25 mm^2	6.55 (0.258)	2.06 (0.081)	10.01 (0.420)	1032 (3386)	0.97 (0.30)
2 Awg	7.42 (0.292)	2.06 (0.08 1)	10.87 (0.454)	935 (3066)	1.07 (0.33)
1 Awg	8.43 (0.332)	2.06 (0.081)	11.89 (0.494)	842 (2762)	1.19 (0.36)
1/0 Awg	9.35 (0.368)	2.06 (0.08 1)	12.80 (0.530)	773 (2562)	1.29 (0.39)
2/0 Awg	10.52 (0.414)	2.06 (0.08 1)	14.00 (0.576)	699 (2294)	1.43 (0.44)

Table 8—EPDM maintenance testing

Values for 1.91 mm (75 mil) insulation thickness 3 kV EPDM					
Conductor	**Conductor diameter**	**Insulation minimum point**	**Calculated insulation diameter**	**IR value 1 km (1 kft)**	**DC leakage 1 km (1 kft)**
Trade size	**mm (in)**	**mm (in)**	**mm (in)**	**MΩ**	**μA/kV**
10 mm^2	3.56 (0.140)	1.73 (0.068)	7.01 (0.302)	719 (2358)	1.39 (0.42)
6 Awg	4.11 (0.162)	1.73 (0.068)	7.57 (0.324)	645 (2118)	1.55 (0.47)
16 mm^2	4.52 (0.178)	1.73 (0.068)	8.01 (0.340)	601 (1972)	1.66 (0.51)
4 Awg	5.18 (0.204)	1.73 (0.068)	8.66 (0.367)	541 (1775)	1.86 (0.56)
25 mm^2	6.55 (0.258)	1.73 (0.068)	10.01 (0.420)	448 (1471)	2.23 (0.68)
2 Awg	7.42 (0.292)	1.73 (0.068)	10.87 (0.454)	405 (1328)	2.47 (0.75)
1 Awg	8.43 (0.332)	1.73 (0.068)	11.89 (0.494)	361 (1185)	2.77 (0.84)
1/0 Awg	9.35 (0.368)	1.73 (0.068)	12.80 (0.530)	333 (1092)	3.00 (0.92)
2/0 Awg	10.52 (0.414)	1.73 (0.068)	14.00 (0.576)	301 (987)	3.33 (1.02)

Copyright © 2005 IEEE. All rights reserved.
HALLIBURTON EXHIBIT 2016
Profrac Holding Corporation and U.S. Well Services, LLC v. Halliburton Energy Services, Inc.
IPR2023-01318, page 22

Table 9—EPDM maintenance testing

Values for 2.29 mm (90 mil) insulation thickness 5 kV EPDM					
Conductor	**Conductor diameter**	**Insulation minimum point**	**Calculated insulation diameter**	**IR value 1 km (1 kft)**	**DC leakage 1 km (1 kft)**
Trade size	**mm (in)**	**mm (in)**	**mm (in)**	**MΩ**	**μA/kV**
10 mm^2	3.56 (0.140)	2.06 (0.081)	7.01 (0.302)	814 (2671)	1.23 (0.37)
6 Awg	4.11 (0.162)	2.06 (0.081)	7.57 (0.324)	734 (2408)	1.36 (0.42)
16 mm^2	4.52 (0.178)	2.06 (0.081)	8.01 (0.340)	685 (2248)	1.46 (0.45)
4 Awg	5.18 (0.204)	2.06 (0.081)	8.66 (0.367)	619 (2031)	1.62 (0.49)
25 mm^2	6.55 (0.258)	2.06 (0.081)	10.01 (0.420)	516 (1693)	1.94 (0.59)
2 Awg	7.42 (0.292)	2.06 (0.081)	10.87 (0.454)	467 (1533)	2.14 (0.65)
1 Awg	8.43 (0.332)	2.06 (0.081)	11.89 (0.494)	421 (1381)	2.38 (0.72)
1/0 Awg	9.35 (0.368)	2.06 (0.081)	12.80 (0.530)	386 (1268)	2.59 (0.79)
2/0 Awg	10.52 (0.414)	2.06 (0.081)	14.00 (0.576)	350 (1147)	2.86 (0.87)

At the completion of the test period, the voltage should gradually be reduced to zero. After the voltage is reduced, the conductor should be solidly grounded. The ground lead should be attached to the conductor under test for sufficient time to allow the conductor to discharge.

The test may be conducted dry or wet on armored cable. However, on unarmored cable, the entire assembly must be submerged.

Recommended test voltages for ESP cable are shown in Table 1. When, in the opinion of the user, it is necessary to use more stringent maintenance test voltages, a higher level should be determined in consultation with the suppliers of the cable. When considering these higher voltages, the user should be aware of the insulation damage resulting from unduly high-voltage stresses.

7. Evaluation of dc high-pot test results

7.1 Current-time relationship

The current indication will momentarily increase for each voltage increment due to the charging of the capacitance and the dielectric absorption characteristics of the cable. Both of these decay: the first, in a few seconds; the latter, more slowly. Ultimately, only the conduction current is left, including any external surface leakage or corona leakage currents. The time required to reach steady state current depends on the insulation temperature, the material, and the cable geometry, whether it is flat or round.

7.2 Interpretation

Considerable experience is needed to properly interpret dc test results. A significant factor is the change of leakage current with time. In general, the current will start relatively high and decline rapidly and should

Copyright © 2005 IEEE. All rights reserved.

HALLIBURTON EXHIBIT 2016
Profrac Holding Corporation and U.S. Well Services, LLC v. Halliburton Energy Services, Inc.
IPR2023-01318, page 23

then become constant at some lower value. That the current becomes constant is more important than the actual magnitude. If the leakage current starts to rise, it is a strong indication that trouble exists. It is usually the practice to continue the test for as long as the leakage current continues to rise, until dielectric failure occurs.

The leakage current curves are based on reaching and remaining at a constant voltage. At this voltage, the leakage current in a good cable will decrease rapidly and then stabilize as shown in Figure 4.



Figure 4—Leakage current in good cable

Deteriorating insulation quality may be observed in Figure 5 where the leakage current begins to rise as the time increases.

Figure 5—Leakage current in bad cable



Copyright © 2005 IEEE. All rights reserved.
HALLIBURTON EXHIBIT 2016
Profrac Holding Corporation and U.S. Well Services, LLC v. Halliburton Energy Services, Inc.
IPR2023-01318, page 24

Various insulating materials may have different leakage currents and still exhibit acceptable performance. For example, polypropylene-insulated cable generally has much lower conductance leakage than does EPDM rubber. Therefore, measuring higher leakage currents from one cable to the next may be the difference in materials and may not indicate deterioration in insulation.

To assist in the interpretation of leakage current, Table 2 through Table 10 provide a set of values for polypropylene and EPDM cables. API RP 11 S6 provides a very good explanation of the method used to calculate these tables. The values are to be used as a guide only, and each operating area may wish to establish a set of values by cable type and well conditions that work for it. When interpreting rubber products, a large variation may be seen from one vendor to the next because of the special compound ingredients used for the unique formulations.

Table 10—Temperature correction factors (TCFs)

Test temperature	Insulation resistance TCF multiplier	DC leakage current TCF multiplier
10 °C (50 °F)	0.75	1.360
15 °C (59 °F)	0.97	1.030
20 °C (68 °F)	1.27	0.780
25 °C (77 °F)	1.66	0.060
30 °C (86 °F)	2.20	0.460
35 °C (95 °F)	2.81	0.360
NOTE—These factors apply to Table 2 through Table 9.		

Step testing of cable requires more than the three to five steps to plot that is generated by the computer. Create a graph of current in microampere versus potential in kilovolts. On the graph, plot the slope of the acceptable dc leakage current. Then plot the microampere conductance at each test voltage. The measured current curve should be completely below the acceptable leakage current line. The equations for conducting the tests have been developed by Durham et al. [B2].

Example

Assume: #2 Awg (33.6 mm^2), EPDM insulation, 2.3 mm (90 mil) thickness

From Table 6: 1.07 μA/kV/1 km (0.33 μÁ/kV/1 kft) = the maximum allowed leakage

If we assume a length of 2000 m (6562 ft) and the readings taken in the test data, then the plot would look like Figure 5.

If we divide the final reading in column 4 by the kilovolt/kilometer (kilovolt/kilofoot), the leakage for the cable is 0.375 μÁ/kV/1 km (0.11 μÁ/kV/1 kft).

The first criterion is to determine the maximum leakage current permissible.

Next plot the measured microamperes versus the impressed kilovolts as shown in Figure 6. For acceptable performance, all values must be below the leakage current line.

Copyright © 2005 IEEE. All rights reserved.

HALLIBURTON EXHIBIT 2016
Profrac Holding Corporation and U.S. Well Services, LLC v. Halliburton Energy Services, Inc.
IPR2023-01318, page 25



Figure 6—Leakage current limit and test curves

7.3 Dielectric failure

If at any time during the test a violent increase in leakage current occurs, failure or flashover has probably occurred in the cable. A failure can be confirmed by the inability of the cable to sustain the reapplication voltage. Once a dielectric failure occurs, the failure should be cut out. If a flashover occurs at the termination, the termination should be repaired.

7.4 Current comparison

The comparison of the leakage currents of the three cable conductors is a useful indication of the insulation condition. However, no clear guidelines for such a comparison can be given. For large values of measured leakage current during maintenance testing, a potential problem is likely if the leakage current is greater than the appropriate values from Table 2 to Table 11 in this recommended practice.

Table 11—Test data

Segment	Impressed kilovolts	Maximum allowed microamperes	Measured microamperes on 2 km (6.26 kft)
0	0.0	0.00	0.00
1	2.3	2.50	1.06
2	4.7	5.00	2.50
3	7.0	7.49	4.35
4	9.3	10.00	6.23
5	11.7	12.50	8.65
6	14.0	15.00	10.50
NOTE—Readings have been rounded.			

Copyright © 2005 IEEE. All rights reserved.
HALLIBURTON EXHIBIT 2016
Profrac Holding Corporation and U.S. Well Services, LLC v. Halliburton Energy Services, Inc.
IPR2023-01318, page 26

Before leakage current was used as a measurement tool, a 3-to-1 ratio was used to compare one phase with another phase regardless of the quantity of leakage. It is very difficult to compare conductor phases using a 3-to-1 ratio as a pass/fail criteria. (Note that this ratio should be used with a great deal of discretion, particularly if microampere meter readings are less than 10 μA.)

In general, meter readings are more accurate above mid-scale because accuracy is normally a percentage of the full-scale reading. Therefore, when possible, select scales so that the readings are on the upper half of the meter. Trying to read a 2 μA value on the low end of a 0–100 μA scale is not accurate. When these low values are observed, it is difficult to compare performance between phases.

All cable insulation exhibits a negative temperature resistance coefficient. Increased temperature will, therefore, always result in increased leakage current.

As noted in 5. 1, testing under conditions of humidity, condensation, or actual precipitation on the cable surfaces can be hazardous. However, if testing must be done under these conditions, there may be an increase in the leakage current. Humidity also increases the corona discharge, which is indicated in the leakage current.

Wind prevents the accumulation of space charges at bare energized terminals, which results in an increase of corona. A plastic bag, silicone sealant, or electrical putty retains this space charge in the presence of wind.

These factors should be considered when comparing and evaluating the apparent dielectric condition of the cable. If leakage currents are high, then further investigation and testing is warranted to determine whether the cable has a high-resistance fault or deteriorating cable dielectric.

8. Conductor resistivity and continuity tests

A test should be performed on all three-phase conductors to determine that their series resistance is balanced and that there are no breaks in any conductor. This test should be conducted by grounding all phase conductors at one end and measuring the resistance to ground of each conductor at the opposite end with an ohmmeter. These resistance values should be well balanced.

9. Mechanical integrity

The primary component to assure mechanical integrity is the cable armor. Mechanical damage or discontinuities may indicate damage to the insulated conductor. Therefore, a thorough visual inspection is recommended.

The primary indications of mechanical damage are absence of armor, crimp marks, corrosion, and deformation. If these conditions are observed, the severity of the defect should be determined and, if necessary, corrected.

10. Testing of surface feedthroughs and connections

10.1 Description

The downhole cable must necessarily transition to a surface connection at some point. The type of transition depends on the installation configuration, and area classification. The surface installation equipment is determined by the likelihood of an electrical failure occurring at the same time that (1) an ignitable vapor is present and (2) the electrical failure will be the source of ignition.

Copyright © 2005 IEEE. All rights reserved.

HALLIBURTON EXHIBIT 2016
Profrac Holding Corporation and U.S. Well Services, LLC v. Halliburton Energy Services, Inc.
IPR2023-01318, page 27

At least three conditions reduce the likelihood of the electrical equipment being the cause of ignition: (1) the presence of other ignition sources, (2) electrical equipment type, and (3) the presence and concentration of ignitable vapors in operating conditions.

The electrical configuration is not intended to control fugitive emissions. Refer to API RP 500 for details; there also may be state regulations that require special consideration.

10.2 Wellhead with feedthrough

If there are no electrical connections, arcing contacts, or heat sources, then the electrical equipment will not be a source of ignition under normal operating conditions.

For these installations, the cable may be simply fed through the wellhead. The termination would be made in a vented junction box. The cable armor, wellhead, and vent box must be adequately grounded to the control panel grounding point. Bonding a copper wire of adequate size to the electrical components normally completes this circuit.

Although the area around the wellhead may be classified as Division 2, the cable is simply passing through the area. To make the area transition, appropriate seals and connections must be applied at the vented junction box.

10.3 Wellhead with connections

Some installations have a connection at the wellhead that may be a source of ignition. The equipment must have approval by a nationally recognized testing laboratory (NRTL).

Wellheads that are not enclosed in areas above ground grade are classified as Class I, Division 2. The connectors, cable, and raceway for these systems must be approved for the area.

It is recognized under National Electrical Code® (NEC®) (NFPA 70), Article 500-3, that there are connectors that have been used for many years without a problem. These connectors are not designed as load break devices, and power must be de-energized before disconnecting the connector; therefore, there is no source of ignition. This same criterion should apply for feedthroughs at the wellhead.

Wellheads that are enclosed or in areas below ground grade are classified as Class I, Division 1. The connectors, cable, and raceways for these systems must be approved by an NRTL.

10.4 Test procedure

The test procedure for surface equipment depends on the installation equipment.

10.4.1 Wellhead with feedthrough

The cable is tested as part of the downhole assembly as stated in this recommended practice.

10.4.2 Wellhead with connections

The components are prepared according to API RP 11S6 or the manufacturers' procedures. The voltage tests are performed in the same manner as other components in this recommended practice.

Copyright © 2005 IEEE. All rights reserved.
HALLIBURTON EXHIBIT 2016
Profrac Holding Corporation and U.S. Well Services, LLC v. Halliburton Energy Services, Inc.
IPR2023-01318, page 28

10.5 Visual inspection

The primary component to assure mechanical integrity is the cable armor. Mechanical damage or discontinuities may indicate damage to the insulated conductor. Therefore, a thorough visual inspection is recommended.

The primary component to assure mechanical integrity is the cable armor. Mechanical damage or discontinuities may indicate damage to the insulated conductor. Therefore, a thorough visual inspection is recommended.

10.6 Procedure

The test procedure for surface equipment depends on the installation equipment.

10.6.1 Unclassified feedthroughs

The cable is tested as part of the downhole assembly as stated in this document.

10.6.2 Division 2 connection

The components are prepared according to API RP 11 S6 or the manufacturer's procedures. The voltage tests are performed in the same manner as other components in this recommended practice.

10.6.3 Division 1 connection

The components are prepared according to API RP 11 S6 or the manufacturer's procedures. The voltage tests are performed in the same manner as other components in this recommended practice.

Copyright © 2005 IEEE. All rights reserved.

HALLIBURTON EXHIBIT 2016
Profrac Holding Corporation and U.S. Well Services, LLC v. Halliburton Energy Services, Inc.
IPR2023-01318, page 29

Annex A

(informative)

Bibliography

[B1] Durham, M. O., Neuroth, D. H., Ashenayi, K., and Wallace, T., "Field test technology relationships to cable quality," *IEEE Transactions on Industry Applications*, vol. 31, no.6, pp. 1381–1389, Nov/Dec. 1995.

[B2] Durham, M. O., Durham, R. A., and Anderson, D., "What are standardized equations for acceptance of hi-pot tests and for voltage drop?" *Institute of Electrical and Electronics Engineers PCIC*, Indianapolis, IN, Sept. 1998.

[B3] IEEE 100, *The Authoritative Dictionary of IEEE Standards Terms,* Seventh Edition, New York, Institute of Electrical and Electronics Engineers, Inc.[9]

[9]IEEE publications are available from the Institute of Electrical and Electronics Engineers, Inc., 445 Hoes Lane, Piscataway, NJ 08854, USA (http://standards.ieee.org/).

Copyright © 2005 IEEE. All rights reserved.
HALLIBURTON EXHIBIT 2016
Profrac Holding Corporation and U.S. Well Services, LLC v. Halliburton Energy Services, Inc.
IPR2023-01318, page 30