

SPEEDFLEX®

TRACK TOP GASKET


**FIRE. SMOKE.
ACOUSTICAL.**

INSTALLATION INSTRUCTIONS

SPEEDFLEX® TRACK TOP GASKET WITH FOLDED LEGS (TTG250F, TTG350F, TTG600F)




1. Pull end of TTG from center of roll. Peel optional adhesive from end.



2. Place TTG at one end of track and center along its entire length.




3. Flip track and cut TTG along other end of track.



4. Secure track to floor/ceiling in the normal manner.

Optionally, secure TTG with integral crack and peel adhesive or with bands of pressure-sensitive tape (e.g. electrical, duct, packing, filament or masking tape).



5. Verify that downward projecting flaps are sandwiched between gypsum board and steel ceiling track. Seams in adjoining lengths of gasket may be butted or overlapped.

LIMITED WARRANTY: STI warrants that its products will be free of defects for one year from the date of purchase. In the event a product does not conform to this warranty, the sole and exclusive remedy is, at STI's option, replacement of the product or refund of the purchase price. The warranty provided herein shall be void and of no effect in the event that the product is not installed in accordance with STI's published instructions, listed systems and applicable building and safety codes. THIS WARRANTY IS IN LIEU OF ALL OTHER REPRESENTATIONS AND EXPRESSED OR IMPLIED WARRANTIES (including the implied warranties of merchantability or fitness for a particular use) AND UNDER NO CIRCUMSTANCES SHALL STI BE LIABLE FOR ANY DIRECT, INDIRECT, SPECIAL, INCIDENTAL OR CONSEQUENTIAL DAMAGES OR LOSSES, INCLUDING, WITHOUT LIMITATION, ANY LOSS OF REVENUE, PROFIT OR USE. Prior to use, the user shall determine the suitability of the product for its intended use, and the user assumes all risks and liability for subsequent use. No person other than an officer of STI is authorized to bind STI to any other warranty for any product for which this warranty is issued.

MADE IN USA • PRINTED IN USA
COPYRIGHT © 2016 SPECIFIED TECHNOLOGIES INC.

U.S. patents apply to this product.
For details visit: www.stifirestop.com/patents

 **Specified
Technologies
Inc.**
THE FIRESTOP AUTHORITY



SpeedFlex® Track Top Gasket
FILL, VOID OR CAVITY MATERIAL CERTIFIED
FOR USE IN JOINT SYSTEMS. SEE UL ONLINE
CERTIFICATIONS DIRECTORY.

Somerville, NJ 08876 USA • US Toll Free: (800) 992-1180 • Outside US: +1 908 526 8000 • www.stifirestop.com
ZIS1240-0107