

Conferences > Conference Record of the 2004... ?

# A controlling method for charging photovoltaic generation power obtained by a MPPT control method to series connected ultraelectric double layer capacitors

Publisher: IEEE Cite This PDF

N. Mutoh ; T. Inoue All Authors

9 Cites in Papers41 Cites in Patents575 Full Text Views

Alerts

Manage Content AlertsAdd to Citation Alerts

Abstract

Document Sections

I. Introduction

II. PV System to Link a Utility and Loads

III. Generation of the Mppt Control Rule Suitable for Edlc Charging Control Systems

IV. MPPT Control Method Using the Linearity between the Maximum Power and Optimal Current

V. Ultra-edlc Charging Method for PV Generation System

Show Full Outline

Authors

Download PDF

Abstract:

A photovoltaic (PV) generation system which can efficiently acquire the electric energy irrespective of the weather is described. The PV generation system is characterize... View more

Metadata

Abstract:

A photovoltaic (PV) generation system which can efficiently acquire the electric energy irrespective of the weather is described. The PV generation system is characterized by two controllers, namely, a maximum power point tracking (MPPT) controller which makes it possible to take the maximum power which solar arrays can generate at any time irrespective of the weather, and a controller which quickly charges the maximum power obtained by the MPPT control to series connected ultraelectric double layer capacitors (ultraEDLCs) while maintaining the electric capacity which solar arrays can generate at that time. The MPPT controller controls the output current of the solar arrays so that the output power converges on the maximum power in the prediction line previously determined based on the linearity between the maximum output power and the optimal current. The MPPT controller is characterized by having the ability to enlarge the controllable range of the output power to lower solar radiation in comparison with the conventional hill-climbing method. The charging controller controls the current and voltage so as to be charged at around the power generated at that time while supervising the maximum voltage and allowable temperature of each series connected EDLC. The combined control method makes it possible to charge with the maximum power generation from solar arrays into ultraEDLCs. Effectiveness of the methods is verified by simulations and experiments.

**Published in:** Conference Record of the 2004 IEEE Industry Applications Conference, 2004. 39th IAS Annual Meeting.

**Date of Conference:** 03-07 October 2004

**DOI:** 10.1109/IAS.2004.1348791

**Date Added to IEEE Xplore:** 01 November 2004

**Publisher:** IEEE

**Print ISBN:** 0-7803-8486-5

**Conference Location:** Seattle, WA, USA

**Print ISSN:** 0197-2618

**References is not available for this document.**

## Contents

### I. Introduction

Studies of photovoltaic (PV) generation systems are actively being promoted in order to mitigate environment issues such as the green house effect and air pollution. PV generation systems have two big problems that the efficiency of electric power generation is very low, especially under low irradiation states and the amount of the electric power generated by solar arrays is always changing with weather conditions, i.e., the intensity of the solar radiation (irradiation). A maximum power point tracking (MPPT) method which has quick response characteristics and is able to make good use of the electric power generated in any weather is needed to solve the former problem. Many MPPT control methods have been proposed that search for the maximum operating conditions from the output power and voltage characteristics of solar arrays using differential techniques like the hill-climbing method or fuzzy rules. However, methods to make the output power generated from the installed solar arrays quickly arrive at its peak value have not been discussed. Although an enhanced hill-climbing method was recently reported [1]–[4], there are difficulties in the algorithms because various parameters are needed during the tracking process. This leads to a larger time to reach the maximum power. A method to refine the response characteristics of the output power was also proposed [2] that searches for the maximum point so that the derivative of the output power with respect to the output voltage of solar arrays becomes zero. However, there are problems in controllability to search for the maximum point at lower irradiation because the derivative of the output power with respect to the output voltage also drops as the irradiation decreases.

Authors

Figures

References

Export ?

References & Cited By

☐ Select All

1. T. Ouchi, H. Fujikawa, S. Masukawa and S. Iida, "A Control Scheme for Three-Phase Current Source Inverter in Interactive Photovoltaic System", *T. IEEE Japan*, vol. 120-D, no. 2, pp. 230-238, 2000.  
[CrossRef](#) [Google Scholar](#)
2. H. Dong, H. Sugimoto and N. Nishio, "A Maximum Power Tracking Control Method for Photovoltaic Power Generation System Based on Derivation of Output Power with Respect to Output Voltage", *T. IEE Japan*, vol. 118-D, no. 12, pp. 1435-1442, 1998.  
[CrossRef](#) [Google Scholar](#)
3. T. Kitano, M. Matsui and D. Xu, "A Maximum Power Point Tracking Control Scheme for PV System Based on Power Equilibrium and its System Design", *T. IEE Japan*, vol. 121-D, no. 12, pp. 1263-1269, 2001.  
[CrossRef](#) [Google Scholar](#)

4. T. Kitano, M. Matsui and D. Xu, "A MPPT Control Scheme for PV System Utility Limit Cycle Operation and Its System Design", *T. IEE Japan*, vol. 122-D, no. 4, pp. 382-389, 2002.

[Google Scholar](#)

5. N. Mutoh, T. Matuo, K. Okada and M. Sakai, "Prediction-Data-Based Maximum-Power-Point-Tracking Method for Photovoltaic Power Generation Systems", *IEEE PES02*, vol. 3, pp. 1489-1494, June 2002.

[CrossRef](#)

[Google Scholar](#)

6. A. Luque and S. Hegedus, "Handbook of Phtovoltaic Sience and Engineering" in , John Willy & Sons, pp. 92-99, Dec. 2002.

[Google Scholar](#)

[View More](#)

Citations



Keywords



Metrics



#### More Like This

Control of Single-Phase Solar Power Generation System With Universal Active Power Filter Capabilities Using Least Mean Mixed-Norm (LMMN)-Based Adaptive Filtering Method

IEEE Transactions on Sustainable Energy

Published: 2020

A Reduced Component Count MLI for Solar Power Generation

2023 10th IEEE International Conference on Power Systems (ICPS)

Published: 2023

[Show More](#)

IEEE Personal Account

CHANGE  
USERNAME/PASSWORD

Purchase Details

PAYMENT OPTIONS  
VIEW PURCHASED  
DOCUMENTS

Profile Information

COMMUNICATIONS  
PREFERENCES  
PROFESSION AND  
EDUCATION  
TECHNICAL INTERESTS

Need Help?

US & CANADA: +1 800  
678 4333  
WORLDWIDE: +1 732  
981 0060  
CONTACT & SUPPORT

Follow



[About IEEE Xplore](#) | [Contact Us](#) | [Help](#) | [Accessibility](#) | [Terms of Use](#) | [Nondiscrimination Policy](#) | [IEEE Ethics Reporting](#)  | [Sitemap](#) | [IEEE Privacy Policy](#)

A not-for-profit organization, IEEE is the world's largest technical professional organization dedicated to advancing technology for the benefit of humanity.

© Copyright 2024 IEEE - All rights reserved, including rights for text and data mining and training of artificial intelligence and similar technologies.

IEEE Account

- » Change Username/Password
- » Update Address

Purchase Details

- » Payment Options
- » Order History
- » View Purchased Documents

Profile Information

- » Communications Preferences
- » Profession and Education

» [Technical Interests](#)

### Need Help?

» **US & Canada:** +1 800 678 4333

» **Worldwide:** +1 732 981 0060

» [Contact & Support](#)

[About IEEE Xplore](#) | [Contact Us](#) | [Help](#) | [Accessibility](#) | [Terms of Use](#) | [Nondiscrimination Policy](#) | [Sitemap](#) | [Privacy & Opting Out of Cookies](#)

A not-for-profit organization, IEEE is the world's largest technical professional organization dedicated to advancing technology for the benefit of humanity.

© Copyright 2024 IEEE - All rights reserved. Use of this web site signifies your agreement to the terms and conditions.